TERRA ENVIRON LABS PVT. LTD
Flat No:- 6-B,6-3-652/D/49, 6th Floor
Dhruvatara Apartments ,Somajiguda
Hyderabad ,Telangana-500082.
GSIN:36AALCT3595K1ZM

TC-17510

Name of the Customer & Address :
St. John's School
Karimnagar, Hyderabad, 9550997126

Report Number : 26/09/02/DW/0001

Date of Report Issue : 11.02.2026

ULR-TC175102600000001F

Sample Registration Number	:	TEL/2026/09/02/DW/0001	**Sample Description**	:	Drinking Water *
Sample Received On	:	09.02.2026	**Quantity Received**	:	1 L
Analysis Starting Date	:	09.02.2026	**Sample Packing**	:	Sealed Bottle
Analysis Completion Date	:	11.02.2026	**Sample Collected & Submitted By**	:	Client *

Discipline: Chemical , **Group:** Water ,**Subgroup** : Drinking Water

TEL/GF/LAB/014

TEST REPORT

S. No.	Test Parameter	Units	Test Method	Results	IS 10500 (2012)	
					Acceptable	Permissible
1	pH @25^{0}C	--	IS 3025 (Part-11) 2022	6.31	6.5 – 8.5	6.5 – 8.5
2	Odour	--	IS 3025 (Part-05) 2018	Agreeable	NS	NS
3	Color	CU	IS 3025(Part -04) 2021	<5	5	15
4	Electrical Conductivity	uS/cm	IS 3025(Part -14) 2013	173	NS	NS
5	Turbidity	NTU	IS 3025 (Part -10) 2023	<1.0	1	5
6	Total Dissolved Solids	mg/L	IS 3025 (Part-16) 2022	96	500	2000
7	Total Hardness	mg/L	IS 3025 (Part -21) 2009	42	200	600
8	Calcium Hardness as CaCo3	mg/L	IS 3025 (Part -40)2024	22	NS	NS
9	Magnesium Hardness as CaCo3	mg/L	IS 3025 (Part-46) 2023	20	NS	NS
10	Calcium as Ca	mg/L	IS 3025 (Part -40)2024	8.8	75	200
11	Magnesium Mg	mg/L	IS 3025 (Part-46) 2023	4.9	30	100
12	Total Alkalinity	mg/L	IS 3025 (Part -23) 2023	36	200	600
13	Chlorides as Cl	mg/L	IS 3025 (Part -32) 2014	21	250	1000
14	Sodium as Na	mg/L	IS 3025 (Part -45)2024	19	NS	NS
15	Potassium as K	mg/L	IS 3025 (Part -45)2024	<10	NS	NS
16	Sulphates as SO_4	mg/L	IS 3025 (Part -24/1) 2024-B	<5.0	200	400
17	Nitrates as NO_3	mg/L	IS 3025(Part -34/sec 1)2023	22	45	NS
18	Silica as SiO_2	mg/L	IS 3025 (Part -35) 2024-B	6.0	NS	NS
19	Iron as Fe	mg/L	IS 3025 (Part -53)2024	<0.1	1.0	NS
20	Fluoride as F	mg/L	IS 3025 (Part -60/sec 1) 2023-B	<0.1	1.0	1.5
21	Phosphorus as P	mg/L	IS 3025 (Part 31/sec 1)2022-C	<0.5	NS	NS
22	Residual Free Chlorine	mg/L	IS 3025 (Part 26)2021	<0.1	0.2	1.0

Note: 1) The above results relate only to the sample tested.
2) Test report shall not be reproduced except in full without approval of the laboratory.
3) *- Details provided by the customer.
4) Disputes are subject to the jurisdiction of Hyderabad only.
5) NS: Not Specified

*** END OF THE REPORT ***

Verified By:
M Nithya Chandana
Technical Manager

TERRA ENVIRON LABS PVT. LTD. HYDERABAD

Authorized Signatory :
Dr Shaik Darga Saheb
Quality Manager

E-mail :terraenvironlabs@gmail.com
Website : terraenvironlabs.com

ISO 9001:2015
ISO 45001:2018
NABL Accredited Laboratory
T: +917037733026

TERRA ENVIRON LABS PVT. LTD
Flat No:- 6-B,6-3-652/D/49, 6th Floor
Dhruvatara Apartments ,Somajiguda
Hyderabad ,Telangana-500082.
GSIN:36AALCT3595K1ZM

Name of the Customer & Address :
St. John's School
Karimnagar, Hyderabad, 9550997126

Report Number : 26/09/02/DW/0001

Date of Report Issue : 11.02.2026

Sample Registration Number	:	TEL/2026/09/02/DW/0001	**Sample Description**	:	Drinking Water *
Sample Received On	:	09.02.2026	**Quantity Received**	:	1 L
Analysis Starting Date	:	09.02.2026	**Sample Packing**	:	Sealed Bottle
Analysis Completion Date	:	11.02.2026	**Sample Collected & Submitted By**	:	Client *

Discipline: Chemical , **Group:** Water ,**Subgroup** : Drinking Water

TEL/GF/LAB/014

TEST REPORT

S. No.	Test Parameter	Units	Test Method	Results	IS 10500 (2012)	
					Acceptable	Permissible
1	Total Coliforms	CFU/100ml	IS 15185	Absent	Shall not be detectable in any 100ml of sample	
2	E. Coil	CFU/100ml	IS 15185	Absent		

Note: 1) The above results relate only to the sample tested.
2) Test report shall not be reproduced except in full without approval of the laboratory.
3) *- Details provided by the customer.
4) Disputes are subject to the jurisdiction of Hyderabad only.
5) NS: Not Specified

*** END OF THE REPORT ***

Verified By:
M Nithya Chandana
Technical Manager

TERRA ENVIRON LABS PVT. LTD. HYDERABAD

Authorized Signatory :
Dr Shaik Darga Saheb
Quality Manager

E-mail :terraenvironlabs@gmail.com
Website : terraenvironlabs.com

ISO 9001:2015
ISO 45001:2018
NABL Accredited Laboratory
T: +917037733026